



*Bids and Awards Committee Office*

**SUPPLEMENTAL / BID BULLETIN  
No. 03 – 2019**

Name of Project : Supply and Delivery of 6-Units of 3-Toner Aircon for STE Rooms  
Contract ID No. : 19PBTNMSC15-G  
PhilGEPS Reference No. : 6653292  
Date of issuance : November 25, 2019

In accordance with Section 22.5.2 of IRR of R.A. No. 9184, this Addendum No. 03 – 2019 is hereby issued to clarify, modify or amend items as stated below:


**A. Technical Specifications:**

<b>From</b>	<b>To</b>
<ul style="list-style-type: none"><li>• Package type, non-inverter, floor standing, 3-tonner, with installation</li><li>• Cooling Capacity: 37,980 kj/Hr</li><li>• Energy Ratio Efficiency: 9.7 kg/W-HR</li></ul>	<ul style="list-style-type: none"><li>• Package type, non-inverter, floor standing, 3-tonner <b>4 HP</b>, with installation</li><li>• Cooling Capacity: <u>minimum 37,000</u> kj/Hr</li><li>• Energy Ratio Efficiency: <u>Minimum 9</u> kj/W-Hr</li></ul> <p>Additional:</p> <ul style="list-style-type: none"><li>• Includes circuit breaker enclosure NEMA</li></ul>

Other specifications/requirements in the original Terms of Reference (TOR) and/or Manual Bidding Documents of the project are retained.

This clarification /addendum is hereby made as an integral part of the Terms of Reference (TOR)/Manual of Bidding Documents for the aforesaid project.

Please be guided accordingly.



*Amethyst M. Talaba*  
**AMYTHYST M. TALABA, MPA**  
BAC Chairperson